



## Weekly Boiler Room Inspection and Maintenance Log

Facility:	Date						
Boiler Number:	Time						
Check for tight closing of fuel valves							
Record shut down timing when gas valve closes							
Check Fuel Linkage							
Check Air Linkage							
Check Indicating Lights and Alarms							
Check Operating Controls							
Check Water Level Controls							
Check Limit Controls and Limit Switches							
Check Safety Controls							
Check Interlock Controls							
Check Low Water cutoff operation							
Check for Leaks							
Check for Noise							
Check for Vibration							
Check for Unusual Conditions							
Check operation of all motors							
Check general burner operation							
Check lubricating oil levels							
Check Flame Scanner Assembly							
Check Ignition System							
Check Flame Signal							
Check Packing Glands							

Comments: \_\_\_\_\_

\* This list consists of recommended inspection/maintenance, it may not include all points of inspection and/or maintenance for the specific boiler room

\* It may be beneficial to expand upon this list for record keeping and maintenance purposes. This list does not guarantee unforeseeable boiler failures, but will contribute to improved boiler maintenance